



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Jalpaiguri Fire Station, Race Course Para, P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo No.:FSR/FSC/0125186237900501

Date : 10-07-2026

From :
Divisional Fire Officer
Jalpaiguri Division,
West Bengal Fire & Emergency Services

To :
DON BOSCO SCHOOL Run By IMPS Educational Trust
MOUZA- UTTAR MOUAMARI, PLOT NO- R.S. 2138, 2139, 2140, 2141, L.R. 2884, 2885, 2886, 2887, J.L. NO- 40, P.S.-
MAYNAGURI, DIST- JALPAIGURI

Sub : Part Fire Safety Certificate for G+2 storied educational Building (FSR issued for G+3 storied educational building) of Don Bosco School Run By Imps Educational Trust having location at MOUZA- UTTAR MOUAMARI, PLOT NO- R.S. 2138, 2139, 2140, 2141, L.R. 2884, 2885, 2886, 2887, J.L. NO- 40, P.S.- MAYNAGURI, DIST- JALPAIGURI

This is in reference to your AIN 211892606300010749 dated 06-Jul-2026 regarding Part Fire Safety Certificate for G+2 storied educational Building (FSR issued for G+3 storied educational building) of Don Bosco School Run By Imps Educational Trust having location at MOUZA- UTTAR MOUAMARI, PLOT NO- R.S. 2138, 2139, 2140, 2141, L.R. 2884, 2885, 2886, 2887, J.L. NO- 40, P.S.- MAYNAGURI, DIST- JALPAIGURI

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

Recommendation

1. Maintenance/checking testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Department shall enter and inspect the industry at any time between sunrise to sunset for ascertaining the contravention if any of Fire Prevention and Fire Safety Measures
3. Mock Drill must be performed twice in a year and recorded properly.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892606300010749

Principal
Don Bosco School
Maynaguri

Billy Bhabha
Chairman
Don Bosco School, Maynaguri

4. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
5. No parking will be allowed on the Driveway.
6. The interior finish decoration of buildings of the industry shall be made with low flame spread material conforming to the I.S. Specification.
7. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the buildings shall be strictly maintained.
8. Existing Electrical wiring of the buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
9. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable areas of the site.
10. The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the industry and to operate in the event of Fire and Testing.
11. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the industry.
12. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the industry.
13. First-Aid Fire Fighting system shall be provided as per I.S. specification.
14. Arrangement shall have to be made for regular checking, testing and maintenance of all the firefighting installation in the industry to keep them in perfectly good working condition at all the times.
15. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
16. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
17. The Fire Safety Audit is to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.
18. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled and no renewal would be made.
19. This Fire Safety Certificate is valid for three years as per existing Govt. Notification and has to be renewed in due time.

Valid Upto: 08-Jul-2029
Memo No.: FSR/FSC/0125186237900501



Signature valid

Digitally Signed
Name: Animesh Das
Date: 10-Jun-2023 17:10:05
Reason: D-Sign
Location: Bhubaneswar

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892606300010749

Principal
Don Bosco School
Maynaguri

Buddhi Bhattacharya
Chairman
Don Bosco School, Maynaguri